

MONTHLY BOARD REPORT FOR WATER AND WASTEWATER TREATMENT PLANTS

September 29, 2014

Report for Month of August - September 2014

The Water & Sewer Committee met on September 19, 2014

Water Treatment Plant:

1. Water Treatment Plant met discharge limit with no problems this month. Report for August 2014 attached.
2. Dominic had the WTP intake screen and pipe cleaned.
3. WTP Filter Media replacement project to commence in October 2014 by Calgon Carbon Corporation.
4. WTP staff has been flushing the dead end areas of water distribution system.

Wastewater Treatment Plant:

1. Wastewater Treatment Plant met all discharge limits with no violations this month. Report for August 2014 attached.
2. Cleaned South Aeration Tank and diffusers.
3. WWTP staff replaced four (4) new valves at Garden Street pump station as part of an upgrade project.
4. Cleaned West Final Clarifier tank.

Fall Street Pump Station upgrade project update:

Thurston Services has been working on the Fall Street pump Station upgrade. As you know this was cover by the Town insurance company. The soffit and fascia has been repaired, gutters will be installed. The new door has been installed and the roof will be replaced the week of September 29.

The exterior building cracks will be resealed and the exterior of the brick will be water tight. It will look like a stucco building exterior finish.

The interior block cracks will be caulked and the interior repainted.

Respectfully submitted,

Michael Pickard, Chief Operator