

MONTHLY BOARD REPORT FOR WATER AND WASTEWATER TREATMENT PLANTS

November 26, 2014

Report for Month of November - 2014

Water Treatment Plant:

1. Water Treatment Plant met discharge limit with no problems this month. Report for October 2014 attached.
2. The influent Sedimentation Sludge Collector chain and flights broke down on October 28, 2014. Parts have been ordered, 2-4 weeks for delivery.
3. WTP entrance space heater heat exchanger failed. Dominic is replacing the heat exchanger.
4. WTP Sedimentation building heater heaters will be replaced by Dominic and Mark.

Wastewater Treatment Plant:

1. Wastewater Treatment Plant met all discharge limits with no violations this month. Report for October 2014 attached.
2. Installed new replacement pump #2 and motor at Garden Pump Station on November 21, 2014.
3. Put the north Aeration Tank back in service.
4. WWTP employees replaced the drive bearings on the Influent screen, Aqua – Screen.
 - The Water / Sewer Committee meet on November 18, 2014.

Respectfully submitted,

Michael Pickard, Chief Operator