

# MONTHLY BOARD REPORT FOR WATER AND WASTEWATER TREATMENT PLANTS

January 1, 2015

## Report for Month of December 2014

### **Water Treatment Plant:**

1. Water Treatment Plant met discharge limit with no problems this month. Report for November 2014 attached.
2. The employees have been replacing the Sedimentation tank trough brackets in preparation for the sludge collector replacement. Parts have been ordered for the sedimentation tanks, 2-4 weeks for delivery.
3. WTP Sedimentation building heaters, (2) have been replaced by Dominic and Mark.

### **Wastewater Treatment Plant:**

1. Wastewater Treatment Plant met all discharge limits with no violations this month. Report for November 2014 attached.
  2. Working with Donald Davis of Barton & Loguidice on plant functions for interim plant turnover.
  3. WWTP employees completed the overhaul of the Influent screen, Aqua – Screen.
  4. Sludge truck has had many tire replacements and repairs.
- The Water / Sewer Committee meet on December 16, 2014.

Respectfully submitted,

Michael Pickard, Chief Operator