



TOWN OF SENECA FALLS

Office of Water & Sewer

130 Ovid Street, Seneca Falls, New York 13148

315-568-6211

www.senecafalls.com

WATER SERVICE REQUIREMENTS

WATER SERVICE REQUIREMENTS FOR SENECA FALLS

1. The pipe to be installed is to be ¾" or 1" K copper, CTS PVC, or Municipex to be approved by the Seneca Falls Water Department.
2. If CTS PVC is installed, it is to be bedded & covered with sand and have a trace wire run alongside the pipe.
3. All water fittings before the meter will be brass with either flared or compression style nuts intended for in ground use.
4. There will be no fittings between the curb stop and the water meter. This means that there has to be a solid length of pipe between the curb stop and water meter unless approved by the Water Department.
5. The meter will be installed in a horizontal position with a shut-off valve before and after the meter closes to the front wall as possible.
6. There will be NO "sweat" style, steel or PVC fittings before the water meter, only compression type or flare type fittings.
7. The water service is to be buried at a depth of 4'6" to the top of the pipe.
8. NO ONE is to operate the curb stop except for the Town of Seneca Falls Water Department Personnel.
9. All work done to the water system is to be inspected by the Seneca Falls Water Department between the hours of 7:00 a.m. – 2:30 p.m. Any work done on weekends/after business hours/or on holidays will still need to be inspected before backfilling. The homeowner/contractor will be billed a minimum of 3 hours for EACH call-out (after hours) for inspection. **An Appointment Must Be Scheduled 24 Hours In Advance with the Superintendent of Water & Sewer by Calling: 315-246-3231 or E-Mail: jtullo@senecafalls.com.**
10. Water Service will NOT be restored unless all work has been inspected by the Town of Seneca Falls Water Department.